

number	107758/01	Replaces	-
Date of issue	15-07-2021	Issued first	15-07-2021
		Report number	201200198

**Declaration  
regarding the efficiency of a shower heat recovery unit**

**DECLARATION OF KIWA**

This declaration is based on a single examination by Kiwa on a product supplied by

**Q-Blue B.V.**

This declaration does not pass a judgment on other products supplied by the manufacturer. The products mentioned below were tested according the procedure according annex U of the NTA 8800+A1.

**Showersave®-QB1-21 Cyclone**

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance ( $\Delta P$ ) (bar)
2	5.8	47	69.4	0.18
3	9.2	73	66.2	0.39
4, 5, 6	12.5	100	62.7	0.66

Allard Slomp  
Product Manager



Kiwa Nederland B.V.

Kiwa Nederland B.V.  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands  
Tel. 088 998 33 55  
Fax 088 998 36 85  
E-mail [info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwaenergy.com](http://www.kiwaenergy.com)

Q-Blue B.V.  
Willem Barentszstraat 5  
7825 VZ EMMEN  
+31 (0) 591 374570  
[info@q-blue.nl](mailto:info@q-blue.nl)  
[www.q-blue.nl](http://www.q-blue.nl)



DECLARATION

