

DECLARATION



number 108024/01 Replaces -
Date of issue 02-04-2021 Issued first 02-04-2021
Report number 210200261

Declaration regarding the efficiency of a shower heat recovery unit

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on products supplied by

Sanura B.V.

This declaration does not pass a judgment on other products supplied by the manufacturer. The products mentioned below were tested according the procedure according annex U of the NTA 8800+A1:2020.

Flatmate SW

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
2	5.8	47	40.2	0.15
3	9.2	73	36.6	0.34

Flatmate DW

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
2	5.8	47	42.6	0.15
3	9.2	73	39.0	0.37

Allard Slomp
Product Manager

Kiwa Nederland B.V.

Kiwa Nederland B.V.
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands
Tel. 088 998 33 55
Fax 088 998 36 85
info@kiwa.com
www.kiwaenergy.com

Sanura B.V.
Atoomweg 7
3542 AA Utrecht
The Netherlands
info@sanura.nl
www.sanura.nl

